



**Location: 72 South Main St.  
Acushnet, MA 02743**

**Phone: 508-992-3542**

**FAX: 508-994-9503**

**Material: 3" Brown  
Processed Base**

Sieve Size		% Passing
Metric	US Customary	
75.0 mm	3"	100
67.5 mm	2 1/2"	100
50.0 mm	2"	99
37.5 mm	1 1/2"	92
25.0 mm	1"	83
19.0 mm	3/4"	67
12.5 mm	1/2"	56
9.5 mm	3/8"	50
4.75 mm	#4	44
2.36 mm	#8	37
1.18 mm	#16	30
0.600 mm	#30	25
0.300 mm	#50	20
0.150 mm	#100	15
0.075 mm	#200	9.5

**Notes:**

1) Testing in accordance with ASTM D422.