



**Location: 998 Reservoir Rd.  
Lunenburg, MA 01462**

**Phone: 978-582-9931**

**FAX: 978-528-7130**

**Material: 1 1/2" Crushed Stone**

Sieve Size		% Passing
Metric	US Customary	
50.0 mm	2"	100
37.5 mm	1 1/2"	92
25.0 mm	1"	47
19.0 mm	3/4"	19
12.5 mm	1/2"	5
9.5 mm	3/8"	2
0.075 mm	#200	0.9
<b>Physical Properties</b>		
Bulk Specific Gravity		2.733
Effective Specific Gravity		2.742
Apparent Specific Gravity		2.757
Absorption (%)		0.33
Dry Unit Weight (lbs/ft <sup>3</sup> )		91.2
Sodium Soundness Loss (%)		0.4
LA Abrasion Loss (%)		18.9
Flat & Elongated 5:1 (%)		5
Fractured Faces (1 / 2)		100 / 100

**Notes:**

- 1) Testing in accordance with C-136/T-27 Sieve Analysis of Fine and Coarse Aggregate