



**Location: 998 Reservoir Rd.
Lunenburg, MA 01462**

**Phone: 978-582-9931
FAX: 978-582-7130**

**Material: 1 1/2" Dense
Graded Base**

Sieve Size		% Passing
Metric	US Customary	
50.0 mm	2"	100
37.5 mm	1 1/2"	99
25.0 mm	1"	84
19.0 mm	3/4"	71
12.5 mm	1/2"	58
9.5 mm	3/8"	50
4.75 mm	#4	34
2.36 mm	#8	24
1.18 mm	#16	17
0.600 mm	#30	13
0.300 mm	#50	10
0.150 mm	#100	9
0.075 mm	#200	6

Notes:

- 1) Testing in accordance with ASTM D422, "Standard Test Method for Particle Size Analysis of Soils"