



**Location: 998 Reservoir Rd.
Lunenburg, MA 01462**

**Phone: 978-582-9931
FAX: 978-582-7130**

Material: Graded Base

Sieve Size		% Passing
Metric	US Customary	
25.0 mm	1"	100
19.0 mm	3/4"	95
12.5 mm	1/2"	77
9.5 mm	3/8"	67
4.75 mm	#4	44
2.36 mm	#8	30
1.18 mm	#16	24
0.600 mm	#30	19
0.300 mm	#50	16
0.150 mm	#100	8
0.075 mm	#200	7
Physical Properties		
Maximum Dry Unit Weight (lbs/ft ³)		132.5

Notes:

- 1) Testing in accordance with ASTM D422 for the sieve analysis.
ASTM D1559 for the proctor evaluation.