



**Location: 998 Reservoir Rd.  
Lunenburg, MA 01462**

**Phone: 978-582-9931  
FAX: 978-528-7130**

**Material: Dry Screenings**

Sieve Size		% Passing
Metric	US Customary	
9.5 mm	3/8"	100
4.75 mm	#4	99
2.36 mm	#8	81
1.18 mm	#16	57
0.600 mm	#30	43
0.300 mm	#50	32
0.150 mm	#100	21
0.075 mm	#200	11.0

**Notes:**

- 1) Testing in accordance with C-136/T-27 Sieve Analysis of Fine and Coarse Aggregate.