



**Location: 998 Reservoir Rd.  
Lunenburg, MA 01462**

**Phone: 978-582-9931  
FAX: 978-528-7130**

**Material: Washed Screenings**

Sieve Size		% Passing
Metric	US Customary	
4.75 mm	#4	99
2.36 mm	#8	66
1.18 mm	#16	38
0.600 mm	#30	22
0.300 mm	#50	11
0.150 mm	#100	7
0.075 mm	#200	3

**Notes:**

- 1) Testing in accordance with C-136/T-27 Sieve Analysis of Fine and Coarse Aggregate
- 2) All testing performed under the direct supervision of NETTCP certified Soil and Aggregate Technician.