



**Location: 875 Phenix Ave
Cranston, RI 02921**

**Phone: 401-942-7300
FAX: 401-943-2780**

Material: Recycled K-Base

Sieve Size		% Passing
Metric	US Customary	
25mm	1"	100
19.0 mm	3/4"	96
12.5 mm	1/2"	82
9.5 mm	3/8"	73
4.75 mm	#4	58
2.36 mm	#8	44
1.18 mm	#16	33
0.600 mm	#30	24
0.300 mm	#50	16
0.150 mm	#100	11
0.075 mm	#200	7

Notes:

- 1) Testing in accordance with C-136/T-27 Sieve Analysis of Fine and Coarse Aggregate,
- 2) All testing performed under the direct supervision of NETTCP certified Soil and Aggregate Technician.
- 3) Testing performed in P.J. Keating's laboratory meeting state specifications.
- 4) Additional information can be provided upon request.